

**IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER
MONITORING REQUIREMENTS NOT MET FOR**

RALEIGH COUNTY PSD PLUTO BRAGG, WV3304152

We are required to monitor your drinking water on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. Between 7/1/2018 and 12/31/2018, we failed to submit the required samples as indicated below.

What should I do?

There is nothing you need to do at this time.

The table below lists the required monitoring and the compliance period.

Required Monitoring	Compliance Period
53, WATER QUALITY PARAMETER M/R (LCR) Required Lead & Copper WQP's Sample Results Not Submitted	7/1/2018 to 12/31/2018

What happened? What is being done? (Describe corrective action)

In reference to violation 2019-9659 & 2019-9660

Please see attached document

For more information, please contact RCPSD at 683-4090
(Contact name) (Phone number)

Or PO Box 1286 Sophia WV 25921
(Mailing address)

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by: **RALEIGH COUNTY PSD PLUTO BRAGG**

State Water System ID #: WV3304152

Date Distributed: 7-31-2019

Violation 2019-9659 & 2019 9660

What happened?

Due to the exceedance of the lead action level of 0.015 mg/l we were required to do additional testing. Testing consisted of one water quality parameter (WQP) sample group taken in the distribution system during November 2018 and February 2019. Another WQP sample group taken at the entry point to the distribution system taken every two weeks beginning in November 2018. These samples were taken but not submitted monthly to the Health Department.

Based upon the schedule given to us by the Health Department that states "submit a corrosion control recommendation plan by 3/31/19 based on the results of the WQP's" we held our results to be submitted with the corrosion control recommendation. Although more samples than were required were taken at the given times, we did not submit them until receiving the violation notice. We then submitted our sample results on 3/4/19 and again on 3/12/19 with our corrosion control plan. It is our understanding that the letter sent by the Health Department has been misinterpreted by several.

What is being done?

We will continue to pull the WQP samples as we have been since November 2018 and submit them monthly.